



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
JCR15	5.6	Upright	SR	5mm	1/2	Brass, Chrome	155, 175, 286 (68, 79, 141)
JCR15	5.6	Upright	QR	3mm	1/2	Brass, Chrome	155, 175, 286 (68, 79, 141)

Prepared for:

SKOP Indústria e Comércio de Aparelhos contra Incêndio, Rua
Braga 57 – Penha Circular, Rio de Janeiro 21011-500, Brazil

Manufacturing Location:

SKOP Indústria e Comércio de Aparelhos contra Incêndio, Rua
Braga 57 – Penha Circular, Rio de Janeiro 21011-500, Brazil

FM Approvals Class: 2016

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3060566

Approval Granted: November 8, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA





Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
JCR15	5.6	Pendent	SR	5mm	1/2	Brass, Chrome	155, 175, 286 (68, 79, 141)
JCR15	5.6	Pendent	QR	3mm	1/2	Brass, Chrome	155, 175, 286 (68, 79, 141)

Prepared for:

SKOP Indústria e Comércio de Aparelhos contra Incêndio, Rua
Braga 57 – Penha Circular, Rio de Janeiro 21011-500, Brazil

Manufacturing Location:

SKOP Indústria e Comércio de Aparelhos contra Incêndio, Rua
Braga 57 – Penha Circular, Rio de Janeiro 21011-500, Brazil

FM Approvals Class: 2017

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3060566

Approval Granted: November 8, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA

