



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
JCR20	8.0	Pendent	QR	3mm	3/4	Brass, Chrome	155, 175, 286 (68, 79, 141)
JCR20	8.0	Upright	SR	5mm	3/4	Brass, Chrome	155, 175, 286 (68, 79, 141)

Prepared for:

SKOP Indústria e Comércio de Aparelhos contra Incêndio
Rua Braga 57 – Penha Circular, Rio de Janeiro 21011-500, Brazil

Manufacturing Location:

SKOP Indústria e Comércio de Aparelhos contra Incêndio
Rua Braga 57 – Penha Circular, Rio de Janeiro 21011-500, Brazil

FM Approvals Class: 2001

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: 3063817

Approval Granted: June 1, 2021

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read "D. B. Fuller".

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062

USA



Member of the FM Global Group

