



Certificate of Compliance

This certificate is issued for the following equipment:

| Model | K | Type | Resp. | Element | NPT (in.) | Finishes | Temperature Ratings °F (°C) |
|-------|-----|---------|-------|---------------|--------------|---------------|-----------------------------------|
| JCR15 | 5.6 | Pendent | QR | Job F3 3mm | 1/2 | Brass, Chrome | 155, 175, 286 (68, 79, 141) |
| JCR15 | 5.6 | Pendent | SR | Job G5 5mm | 1/2 | Brass, Chrome | 155, 175, 286 (68, 79, 141) |

Prepared for:

SKOP Indústria e Comércio de Aparelhos contra Incêndio
Rua Braga 57, Penha Circular, Rio de Janeiro 21011-500, Brazil

Manufacturing Location:

SKOP Indústria e Comércio de Aparelhos contra Incêndio
Rua Braga 57, Penha Circular, Rio de Janeiro 21011-500, Brazil

FM Approvals Class: 2017

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3030565

Approval Granted: September 12, 2012

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.

A handwritten signature in dark ink, appearing to read 'Richard B. Dunne', is written over a horizontal line.

Richard B. Dunne
Group Manager± Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group